



Environmental Hazards Services, L.L.C.  
7469 Whitepine Rd  
Richmond, VA 23237  
Telephone: 800.347.4010

## Lead in Drinking Water Analysis Report

Client: LEW Corp  
181 US Hwy 46  
Mine Hill, NJ 07803

Report Number: 22-05-04359

Received Date: 05/23/2022  
Reported Date: 05/27/2022  
Sampled By: Andrew Wong  
Tech Certification #:

Project/Test Address: 220430; Asbury Park HS Stadium; Asbury Park, NJ

Client Number:  
201327

# Laboratory Results

Fax Number:  
Ext 18 Melissa

Lab Sample Number	Client Sample ID	Collection Date	Collection Location	Concentration ug/L (ppb)	Analysis Date	Narrative ID
22-05-04359-001	STD 1-BWC-AP	05/21/2022	ONLY BUBBLER IN ONE LOCKER ROOM	<1.00	05/26/2022	
22-05-04359-002	STD 2-CW-AP	05/21/2022	BUBBLER 1 IN OTHER LOCKER ROOM	4.05	05/26/2022	
22-05-04359-003	STD 3-BWC-AP	05/21/2022	BUBBLER 2 IN OTHER LOCKER ROOM	1.12	05/26/2022	
22-05-04359-004	STD 4-SRS-AP	05/21/2022	SUN ROOM SINK	<1.00	05/26/2022	

Method: EPA 200.8  
Analyst: Allison Rodriguez  
Accreditation #: NJ VA008

Reviewed By Authorized Signatory:

*Melissa Kanode*

Melissa Kanode

QA/QC Clerk

Sample Results denoted with a "less than" (<) sign contain less than the reporting limit which is 1 ppb.

The EPA Maximum Contaminant Level for Lead in Drinking Water is 15 ppb. The results herein conform to NELAC standards, where applicable, unless otherwise narrated on this report. Results represent the analysis of samples submitted by the client. Sample location, description, field parameter results, etc., were provided by the client. This report cannot be reproduced, except in full, without written approval from Environmental Hazards Services, L.L.C.

LEGEND ug/L= micrograms per liter ppb = parts per billion